




噴灌計算式：

噴頭名稱	操作壓力	噴灑角度	噴灑半徑	噴灑水量	SV1		SV2		SV3		SV4		SV5		SV6		SV7		SV8		SV9		
	bar		M	LPM	數量	用水量	數量	用水量	數量	用水量	數量	用水量	數量	用水量	數量	用水量	數量	用水量	數量	用水量	數量	用水量	
10Q	2	90	2.7	2.7		0		0		0		0		0	3	8.1		0		0		0	
12Q			3.6	2.19		0		0		0	1	2.19	1	2.19	3	6.57		0		0		0	
15Q			4.5	3.4		0		0		0		0		0		0		0	1	4.5		0	
18Q			5.4	5		0		0		0		0	1	5		0		0	1	5.4		0	
4H		180	1.2	1.7		0		0		0		0	4	6.8	2	3.4		0	1	1.2	3	5.1	
6H			1.8	2.2		0		0		0		0	2	4.4	1	2.2		0	5	9	4	8.8	
8H			2.3	4.4		0		0		0		0		0	1	4.4		0	3	6.9	3	13.2	
10H			2.7	5.3		0		0		0		0	2	10.6	3	15.9	1	5.3	1	2.7	9	47.7	
12H			3.6	4.37		0		0		0		0	2	8.74	2	8.74	1	4.37	1	3.6		0	
15H			4.5	6.9		0		0		0	6	41.4	1	6.9	3	20.7	2	13.8	4	18		0	
18H			5.4	9.9		0		0		0	6	59.4	4	39.6	1	9.9	8	79.2	3	16.2		0	
5000-1.5A		40-360	10.2	4.8		0		0		0		0		0		0	1	4.8		0		0	
5000-6A		40-360	12.4	17.4		0		0		0		0		0		0	1	17.4		0		0	
9.50E-24	4.1	40-345	23.8	136.0		1	136	1	136	1	136		0		0		0		0		0		
小 計 (只/LPM)					1	136	1	136	1	136	13	103	17	84.23	19	79.91	14	124.9	20	67.5	19	74.8	
合 計					噴頭總數量				105				用水總量(L)				942						
每次噴灑時數 (分鐘)					3																		
每次噴灑用水量 (公升)					2826.9																		
每天噴灑次數 (次)					2																		
每天噴灑用水量 (公升)					5653.8																		
水源小於 2" 請配置 儲水桶最小容量(公升)					2826.9																		